

DECLARATION DE CONFORMITE DECLARATION OF CONFORMITY

N° A 2034 16

APPAREIL(S) : Disjoncteurs DX³ 6000kA et 10000kA
SAMPLE DESCRIPTION : MCBs DX³ 6000kA - 10000kA

REFERENCE(S) :
REFERENCE(S) :

CARACTERISTIQUES :
RATED CHARACTERISTICS :

CET (CES) APPAREIL(S) EST (SONT) CONFORME(S) :
THIS (THESE) DEVICE(S) IS (ARE) IN ACCORDANCE WITH :

LEGRAND atteste sous sa responsabilité qu'il est possible d'utiliser en courant continu les disjoncteurs DX³ Legrand (1P/2P/3P/4P – courbes B, C) habituellement utilisés en réseau 230/400 V ~. Il faut, dans ce cas, tenir compte des déclassements ou précautions indiquées en pièces jointes.

LEGRAND declare under our responsibility that it is allowed to use in direct current the DX3 Legrand m.c.b.'s (1P/2P/3P/4P – B, C curves) which are usually employed at 230/400 V~, by taking care to apply following recommendations and deratings in attached file.


Cette déclaration comprend : 1 page

This declaration contains : 1 page

Date de délivrance : 05/07/2016
Issue date :

Directeur Développement SBU Distribution d'Energie
Development director of Energy Distribution SBU

M. Marcello RE



La reproduction de ce document n'est autorisée que sous la forme de fac-similé photographique intégral. Toute reproduction partielle ou toutes insertions de résultats dans un texte d'accompagnement en vue de leur diffusion doit recevoir un accord préalable et formel de LEGRAND. Ce document résulte d'essais effectués sur un échantillon. Il ne préjuge pas de la conformité des produits fabriqués à l'objet essayé.

This document shall not be reproduced, except as a complete photographic facsimile. Any partial reproduction, as well as the insertion of any results into an accompanying text for distribution, requires the prior written approval of LEGRAND.

This document contains results related only to the items tested. It does not imply the conformity of the whole production to the items tested.

LEGRAND - 128, Avenue du Mal-de-Lattre-de-Tassigny - F 87045 LIMOGES Cedex - Tél. : (33) 05.55.06.84.66