

PRODUCT-DETAILS

XT2H 160 MA 52 Im=314...728 3p F F

XT2H 160 MA 52 Im=314...728 3p F F



General Information

Extended Product Type	XT2H 160 MA 52 Im=314...728 3p F F
Product ID	1SDA067777R1
EAN	8015644016739
Catalog Description	XT2H 160 MA 52 Im=314...728 3p F F
Long Description	C.BREAKER TMAX XT2H 160 FIXED THREE-POLE WITH FRONT TERMINALS AND MAGNETIC RELEASE MA Iu 52 A I3=314...728 A

ABB EcoSolutions

ABB EcoSolutions	Yes
------------------	-----

Circular Value

Circular Design Principles Recyclability Rate	Design for Closing Resource Loops - Standard EN45555 - 58.1 %
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
End of Life Instructions	9AKK108468A2348
Group Waste to Landfill	UL 2799 Zero Waste To Landfill Validation available

**Target**

Toxic Substances Control Act - TSCA	9AKK108467A8326
-------------------------------------	-----------------

**Eco Transparency**

Environmental Product Declaration - EPD	9AKK108468A1891
---	-----------------

**Environmental**

Environmental Information	9AKK108467A6707
REACH Declaration	9AKK108466A1425
RoHS Information	9AKK108466A1424
RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019

**Ordering**

Order Code US and Canada	XT2HE3052MFF000XXX
EAN	8015644016739
Minimum Order Quantity	1 piece
Customs Tariff Number	85362090

**Dimensions**

Product Net Width	90 mm
Product Net Height	130 mm
Product Net Depth / Length	82.5 mm
Product Net Weight	1.4 kg

**Container Information**

Package Level 1 Units	box 1 piece
Package Level 1 Width	130 mm
Package Level 1 Height	208 mm
Package Level 1 Depth / Length	145 mm
Package Level 1 Gross Weight	1.658 kg
Package Level 1 EAN	8015644016739

**Additional Information**

Circuit Breaker Type to be Associated	Motor Protection
Connecting Capacity Main Circuit	Busbar 32.5..100 mm <sup>2</sup>
Current Type	AC/DC
Electrical Durability	120 cycles per hour

	8000 cycle
Mechanical Durability	240 cycles per hour 25000 cycle
Number of Poles	3
Opening Time	CB with SOR 15 ms CB with UVR 15 ms
Order Multiple	1 piece
Power Loss	at Rated Operating Conditions per Pole 4.8 W
Product Main Type	SACE Tmax XT
Product Name	Moulded Case Circuit Breaker
Product Type	Automatic Circuit Breaker
Rated Current ( $I_n$ )	52 A
Rated Frequency (f)	50 / 60 Hz
Rated Voltage ( $U_r$ )	690 V
Rated Impulse Withstand Voltage ( $U_{imp}$ )	8 kV
Rated Instantaneous Short-Circuit Current Setting ( $I_s$ )	312...728 A
Rated Insulation Voltage ( $U_i$ )	1000 V
Rated Operational Voltage	690 V AC 500 V DC
Rated Service Short-Circuit Breaking Capacity ( $I_{cs}$ )	(220 V AC) 100 kA (230 V AC) 100 kA (240 V AC) 100 kA (380 V AC) 70 kA (415 V AC) 70 kA (440 V AC) 65 kA (500 V AC) 50 kA (525 V AC) 30 kA (690 V AC) 15 kA (250 V DC) 2 Poles in Series 70 kA (500 V DC) 3 Poles in Series 70 kA
Rated Ultimate Short-Circuit Breaking Capacity ( $I_{cu}$ )	(220 V AC) 100 kA (230 V AC) 100 kA (240 V AC) 100 kA (380 V AC) 70 kA (415 V AC) 70 kA (440 V AC) 65 kA (500 V AC) 50 kA (525 V AC) 30 kA (690 V AC) 15 kA (250 V DC) 2 Poles in Series 70 kA (500 V DC) 3 Poles in Series 70 kA
Rated Uninterrupted Current ( $I_u$ )	160 A
Recommended Screw Driver	Main Circuit M6
Release	MA
Release Type	M
Short-Circuit Performance Level	H
Standards	IEC
Sub-type	XT2
Terminal Connection Type	Front
Terminal Type	Bolt
Tightening Torque	6 N·m
Version	F
CAD Dimensional Drawing	1SDH002230A1001

## Certificates and Declarations

ATEX Certificate	No certification needed
Data Sheet, Technical Information	1SDC210100D0206 1SDC210099D0206
Declaration of Conformity - CE	9AKK106713A5901
GL Certificate	1SDL000163R0093
LR Certificate	1SDL000163R0100
UL Certificate	No certification needed
VDE Certificate	No certification needed
Dimension Diagram	1SDH000721R0100
Mechanical Drawings	1SDH000721R0100
Wiring Diagram	1SDM000068R0001
Instructions and Manuals	1SDH000721R0001

## Classifications

ETIM 7	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 8	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 9	EC000228 - Power circuit-breaker for trafo/generator/installation protection
IDEA Granular Category Code (IGCC)	4932 >> 3 Pole Non-Interchangeable Trip Electronic Circuit Breakers
Object Classification Code	Q
UNSPSC	39121616
WEEE Category	5. Small Equipment (No External Dimension More Than 50 cm)
eClass	V11.1 : 27370409

## Categories

Low Voltage Products and Systems → Circuit Breakers → Moulded Case Circuit Breakers → Tmax XT

